

# TEST CERTIFICATE

## Determination of the anti-slip property of floor coverings in workrooms and fields of activities with slip danger

Tested material: **wood/wood composite material**

Kind of material (wood): Oak parquet element with on-site sealing  
Article description: Bona Traffic HD Anti-slip  
Dimensions: length, width and thickness variable,  
test specimen: 1000 x 500 x 27 [mm]  
(oak parquet elements 1000 x 232 x 14 [mm],  
cover width 215 mm)

Colour: oak light  
Surface: even, fine-rough structured, factory-sealed  
(consumption: ca. 8-10 m<sup>2</sup>/litre = 120-100 g/m<sup>2</sup>)

Remark: manufacturer's processing recommendation:  
1 x Bona primer (for example Bona Classic, Bona Intense),  
2 x Bona Traffic HD Anti-slip

Producer/supplier: Bona AB  
Murmansgatan 130  
200 21 Malmö  
SWEDEN

Client: Bona Vertriebsgesellschaft mbH Deutschland  
Jahnstraße 12  
65549 Limburg

Certificate No.: 92292001.001e

Test date: 23.11.2020

Sampling: Sent by the customer to the research institute


Test method: **DIN 51130** (edition 02/2014)  
"Testing of floor coverings - Determination of the anti-slip property - Workrooms  
and fields of activities with slip danger - Walking method - Ramp test"  
The test material was delivered in a ready-to-test surface condition.

Test result: Average total acceptance angle: **13,8°**

Assessment: **Classification group of anti-slip property: R10**

**SÄUREFLIESNER-VEREINIGUNG E. V.**  
Institut für Wand- und Bodenbeläge  
Managing Director

  
Dipl.-Ing. Friedrich Höltekemeyer



Großburgwedel, 14.12.2020  
Schu/ed

This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The certificate is given for 5 years (starting from test date). Publication and reproduction of this certificate is only allowed in unabridged form.



– Institut für Wand- und Bodenbeläge –  
**SÄUREFLIESNER-VEREINIGUNG E.V.**

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de  
Nach DIN EN ISO/IEC 17025 durch die DAkKS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00  
aufgeführten Bereiche. Nach DIN EN ISO 9001 unter der Kenn-Nr. NDS 80 zertifiziert und nach EN ISO 9001 zertifizierte Stelle Nr. 18372

